

OFFICE USE ONLY
 Log No. 24599
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1659

1. OWNER Jack Bennett ADDRESS AT WELL LOCATION Hercules Gap
 MAILING ADDRESS 44 Greendale Court
Las Vegas, Nevada 89121
 2. LOCATION NW 1/4 Sec. 8 T. 17 N. R. 63 E White Pine County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sedimentary Gravel & Boulders		0	20	20
Clay		20	40	20
Loose Gravel		40	54	14
Water Bearing Gravel X		54	56	2
Clay & Gravel		56	110	54
Water Bearing Gravel X		110	113	3
Clay		113	120	7

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 120 feet
 Casing record _____
 Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 50 feet
 Perforations:
 Type perforation Factory & Torch
 Size perforation 1/8" x 3" 6 Rows
 From 60 feet to 120 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue, Ely, Nev. 89301 Contractor
 Nevada contractor's license number 14790
 Nevada contractor's drillers number 641
 Nevada driller's license number 641 Actual Driller
 Signed Gerald D. Christiansen Contractor
 Date MAY 13, 1983

Date started May 7, 1983
 Date completed May 9, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test ~~WATER TEST~~
 G.P.M. 20 Draw down 48 feet 1/2 hours
 G.P.M. 25 Draw down 68 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours