

Also # 24621  
 OFFICE USE ONLY  
 Log No. 24619  
 Permit No. ....  
 Basin.....

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Royce Switzer & Steve May ADDRESS Wendover Utah

2. LOCATION W 1/4 Sec 3 T. 36 N/S R. 19 E. Elk County  
 PERMIT NO. 1-1-7

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material         | Water Strata | From | To | Thick-ness |
|------------------|--------------|------|----|------------|
| Gravelly Soil    |              | 0    | 2  |            |
| Coarse Gravel    |              | 2    | 37 |            |
| 1" gravel        |              | 37   | 39 |            |
| Coarse Gravel    |              | 39   | 55 |            |
| Lignite Boulders | X            | 55   | 65 |            |
| 1" gravel        | X            | 65   | 67 |            |
| Coarse gravel 3" | X            | 67   | 73 |            |
| Quartz Boulders  |              | 73   |    |            |

8. WELL CONSTRUCTION  
 Diameter hole 10 inches Total depth 74 feet  
 Casing record.....  
 Weight per foot..... Thickness 158  

| Diameter         | From          | To             |
|------------------|---------------|----------------|
| <u>10</u> inches | <u>1</u> feet | <u>74</u> feet |
| ..... inches     | ..... feet    | ..... feet     |
| ..... inches     | ..... feet    | ..... feet     |
| ..... inches     | ..... feet    | ..... feet     |
| ..... inches     | ..... feet    | ..... feet     |
| ..... inches     | ..... feet    | ..... feet     |

 Surface seal: Yes  No  Type gravel  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 74 feet  
 Perforations:  
 Type perforation Jetted  
 Size perforation 1/2" x 1 3/4"  
 From 50 feet to 74 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

9. WATER LEVEL  
 Static water level 53 Feet below land surface 53  
 Flow..... G.P.M.  
 Water temperature well ° F. Quality Good

Date started May 8, 1983  
 Date completed May 16, 1983

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RD Reynolds  
 Address Wells Nevada  
 Nevada contractor's license number 019440  
 Nevada driller's license number 2161  
 Signed [Signature]  
 Date 5/16/83

BAHER TEST  
 G.P.M. 15 Draw down 10 feet 4 hours  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours