WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

OFFICE USE ONLY
Log No. 22648 (B. 1/2)
Permit No. 43629
Basin SPANISH SPRINGS V. (6-85)

PRINT OR TYPE ONLY Spring Creek Please complete this form in its entirety

NOTICE OF INTENT NO. 2758

1. OWNER Pyramid Ranch Homes
MAILING ADDRESS
ADDRESS AT WELL LOCATION Pyramid Highway
no address given

2. LOCATION SE ¼ NE ¼ Sec. 21 T. 20 N/S R. 20 E Washoe County
PERMIT NO. 43629 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. ~~8"-6"-5"~~ PROPOSED USE Quasi. Municipal: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	4	4
Hard fractured val rock		4	65	61
Hard packed sandy clay		65	90	25
valcanic rock	X	90	115	25
Sandy clay	X	115	195	80
Hard fractured val rock	X	195	260	65
Hard clay		260	295	35
Val Rock	X	295	335	40
Granite type rock	X	335	402	67
sandstone type rock		402	579	177
soft sandstone		579	660	81
fractured Val Rock	X	660	678	18
soft gray rock		678	697	19
Hard black val rock		697	763	66
gravel filled 663 to 763				

Date started 5-8, 1983
Date completed 6-6, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. ~~8"-6"-5"~~ WELL CONSTRUCTION
Diameter hole ..... inches Total depth 763 feet
Casing record 8⅝ .188 6⅝ .156
Weight per foot ..... Thickness 5⅝ .156

Diameter	From	To
8⅝ O.D. inches	0 feet	304 feet
inches	feet	feet
6⅝ O.D. inches	263 feet	503 feet
inches	feet	feet
5⅝ inches	354 feet	663 feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement grout
Depth of seal 264 ft feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation None
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 4 feet below land surface
Flow approx 200 G.P.M. ..... P.S.I.
Water temperature Cal. ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams + Sons (Contractor)
Address 22 So Patterson #1, Sparks (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957
Signed Paul E Williams (Actual Driller)
Date 6-12-83 (Contractor)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434