WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 74658
Permit No. TEST
Basin Truckee Meadows (6-87)

1. OWNER Division of Earth Science ADDRESS 255 Bell St Suite 200 Reno NV 89503

2. LOCATION C ¼ NW ¼ Sec. 26 T. 19 N/S R. 19 E County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium Brown Clay		0	15	15
w/ Sands + Gravel		1		
White Tan Sandstone		15	20	5
Blue Siltstone		20	40	20
Blue Clay + Siltstone		40	140	100
Blue Siltstone		140	440	300
Blue Siltstone + Brown		440	480	40
White Clay		[redacted]	[redacted]	
Blue Clay Siltstone		480	500	20
Reddish Clay Smells		500	560	60
of H_2S w/ Blue				
Siltstone				
Blue Andesite Altered	560	560	700	140
Blue Unaltered Andesite		700	800	100

Date started 5-23, 19 83
Date completed 5-27, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6½ inches Total depth 800 feet
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
2½ inches	0 feet	800 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type NEAT CEMENT
Depth of seal 700 FT feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 700 feet to 800 feet

Perforations:
Type perforation Cutting Torch
Size perforation ¼ x 3 x 3 Space x ¼ x 3
From 760 feet to 800 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 90 Feet below land surface 560
Flow ..... G.P.M.
Water temperature 112 °F. Quality Poor

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred S Anderson
Address 711 W 1400 So Woods Cross Utah 84087
Nevada contractor's license number 015043
Nevada driller's license number 01325
Signed Fred S Anderson
Date 6-13-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627