

OFFICE USE ONLY
 Log No. 24669
 Permit No. DWBS7C
 Basin WHEAS SPRINGS V. (6-84)

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1369

1. OWNER HARLEY FILER ADDRESS AT WELL LOCATION 2600 TWIN SPRINGS -- PALOMINO VALLEY
 MAILING ADDRESS 2600 TWIN SPRINGS PALOMINO VALLEY -- RENO, NV. 89510

2. LOCATION NW 1/4 NW 1/4 Sec. 30 T 22 N/S R. 22 E WASHOE County
 PERMIT NO. 77-300-07 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	15	15
Altered Volcanic Rock & gray & yellow clays		15	496	481
Gray clay layer		496	520	24
Volcanic Rock, gray & black--some yellow chips X		520	625	105
T.D. 625 ft.				
XXXXXXXXXX				

8. 10 5/8" -- 55' WELL CONSTRUCTION
 Diameter hole 7 7/8 inches Total depth 592 feet
 Casing record 6 5/8"
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 18"</u> feet	<u>592</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to T.D. feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3

From	feet to
<u>548</u>	<u>592</u>
feet to	feet
feet to	feet
feet to	feet

9. WATER LEVEL
 Static water level 304 feet below land surface
 Flow 7 G.P.M. P.S.I.
 Water temperature 80 ° F. Quality

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE, INC. Contractor
 Address 2252 GLENDALE AVE. -- SPARKS, NV. Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132 ~~XXXXXX~~
 Nevada driller's license number 1132 & 1379 Actual Driller
 Signed R. M. Thrall Contractor
 Date 6/17/83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air lift for <u>8</u> hours to clean and develop. Well would not clean with air lift method. Color is orange			

BAILER TEST

G.P.M.	Draw down	feet	hours