

OFFICE USE ONLY
 Log No. 24674
 Permit No. DOMESTIC
 Basin LEMON VALLEY (EAST) (92-B)

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1399

PRINT OR TYPE ONLY

1. OWNER ROY ARNESON / JIM ORRICK ADDRESS AT WELL LOCATION 7810 Tamra
 MAILING ADDRESS 2400 4 th Street
Sparks, Nevada 89431 Reno, Nevada 89506
 2. LOCATION SE 1/4 SE 1/4 Sec. 3 T. 20N N/S R. 19 E Washoe County
 PERMIT NO. Golden Valley Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG		0	7	7
Gray hard granite		7	95	88
Fractured granite	x	95	96	1
Gray granite, hard		96	170	74
Fractured granite	x	170	181	11
Gray granite		181	186	5
Fractured granite	x	186	200	14
Water Strata (95-96)		10 GPM		
" " (170-181)		10 GPM		
" " (186-195)		5 GPM		

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 200 feet
 Casing record 200
 Weight per foot 156 Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 200 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 143 feet to 153 feet
 From 174 feet to 196 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 6-683, 19_____
 Date completed 6-10-83, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow 25 G.P.M. P.S.I.
 Water temperature cold °F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, Nevada 89510
 Contractor
 Nevada contractor's license number 14043
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller
 Signed James C. Hoffman
 Contractor
 Date June 13, 1983