

OFFICE USE ONLY
 Log No. 24676
 Permit No. DOMESTIC
 Basin LEMMON V. EAST (92-B)

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1397

PRINT OR TYPE ONLY

1. OWNER BOB FUSCO ADDRESS AT WELL LOCATION
 MAILING ADDRESS 11015 Heart Pine Heart Pine & Nectar
Reno, Nevada 89506 Reno, Nevada 89506
 2. LOCATION SE 1/4 SE 1/4 Sec. 23 T. 21N N/S R. 19 E Washoe County
Lemmon Valley
 PERMIT NO. _____ Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Brown clay		3	60	57
D.G.		60	70	10
Gray granite		70	129	59
Broken granite	X	129	147	18
Gray granite		147	155	8
Water Strata (131-147)				

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 155 feet
 Casing record 155
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>155</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 155 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 129 feet to 151 feet
 From _____ feet to _____ feet

Date started 5-30-83, 19_____
 Date completed 5-31-83, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 60 feet below land surface
 Flow 20 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno Nevada 89510
 Contractor
 Nevada contractor's license number 14043
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller
 Signed Wayne C. Helman
 Contractor
 Date June 9, 1983.

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

OFFICE USE ONLY
 Log No. 24675
 Permit No. AWR-17c
 Basin LEMMON VALLEY (92-B)

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1400

PRINT OR TYPE ONLY

1. OWNER JIM ROLLINS ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS 11015 Deodar
Reno, Nevada 89506

2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 23 T. 21N N/S R. 19 E. Washoe County
Lemmon Valley
 PERMIT NO. _____ Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Brown clay		3	45	42
DG brown clay mixed		45	70	25
Brown clay		70	109	39
Med. sand & gravel	x	109	130	21
Brown clay		130	134	4
Water Strata (109-130)				

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 134 feet
 Casing record 134
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>134</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 134 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 105 feet to 126 feet
 From _____ feet to _____ feet

Date started 5-31-83, 19_____
 Date completed 6-1-83, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 60 feet below land surface
 Flow 30 G.P.M. _____ P.S.I.
 Water temperature cold °F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, Nevada 89510
Contractor
 Nevada contractor's license number 14043
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
Actual Driller
 Signed Sary C. Hedman
Contractor
 Date June 9, 1983.