

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER DANNY LAWRENCE ADDRESS AT WELL LOCATION NE, NW, 16, 12425R
 MAILING ADDRESS H-3 MASON YERINGTON, NEV. 89447
 2. LOCATION NE 1/4 NW 1/4 Sec. 16 T. 12 S. R. 25 E. Lyon County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT FILL w/ ROCK		0	32	32
SILT FILL w/ FEW ROCK		32	75	43
SILT FILL, ROCK w/CLAY		75	80	5
GRAVEL FILL AND ROCK	<u>75</u>	80	118'6"	38'6"

8. WELL CONSTRUCTION
 Diameter hole 10 5/8 inches Total depth 119'6" feet
 Casing record _____
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>1</u> feet	<u>118'6"</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type CEMENT GROUT
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 118'6" feet
 Perforations:
 Type perforation SAWRD
 Size perforation 3/32" X 3" X 6 Rows
 From 98'6" feet to 118'6" feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 45' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name OGDEN BROS. DRILLING
162 No. Bybee Avenue
 Address Yerington, Nevada 89447
 Contractor _____
 Nevada contractor's license number 15646
 Nevada contractor's drillers number _____
 Nevada driller's license number 870 Actual Driller
 Signed Billy Ogden Contractor
 Date 6-22-83

Date started 6-11 1983
 Date completed 6-17 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 26 Draw down 5 feet 1/2 hour
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours