WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24704
Permit No. DOMESTIC
Basin DAYTON V. (8-103)

1. OWNER GENE MUSGRAVE ADDRESS 9550 Hwy 50 W
Silver Springs, Nev. 89429
Parcel "A" MAP 73984

2. LOCATION ¼ ¼ Sec. 3 T. 17 N/S R. 23 E. 240N County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	10	10
SANDY CLAY GRAVEL		10	87	77
SAND WATER	87	87	80	3
SANDY CLAY GRAVEL		80	90	10
SAND + GRAVEL WATER	90	90	110	20
CLAY GRAVEL		110	120	10
SAND GRAVEL WATER	120	120	150	30

Date started 6-24, 1983
Date completed 6-28, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 95 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 150 feet
Casing record BLANK TO 120
Weight per foot 16.94 Thickness .188

Diameter	From	To
12 inches	0 feet	50 feet
10 inches	50 feet	147 feet
8 inches	147 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 147 feet

Perforations:
Type perforation MACHINE
Size perforation 3/32
From 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE PUMP SALES & SERVICE
Address 5551 Highway 50 E, 15
Carson City, Nev. 89701

Nevada contractor's license number 15489

Nevada driller's license number 561

Signed James W Thompson

Date 7-6-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627