

**CALL JIM NANNIS**  
**PRINT OR TYPE ONLY 532-8535** **WELL DRILLERS REPORT**  
Please complete this form in its entirety

NOTICE OF INTENT NO. 1769

1. OWNER McDERMITT CHURCH ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS BOX 337  
McDERMITT, NEV. 89421

2. LOCATION SW 1/4 NW 1/4 Sec. 9 T. 47 N/S R. 38 E. HUMBOLDT County  
PERMIT NO. LOT 10 & 11 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation   
Municipal  Industrial  Test  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>TOP</del> TOP SOIL		0	4	4
SAND		4	7	3
FREE GRAVEL 1st WATER		7	10	3
GRAVEL		10	13	3
LG. GRAVEL		13	16	3
TAN CLAY		16	39	23
ROCK		39	40	1
GRAVEL WATER		40	50	10
BR. CLAY		50	85	35
GRAVEL-CLAY		85	90	5
BR. CLAY		90	110	20
SM. GRAVEL-GREY CLAY		110	130	20
LG. GRAVEL SEVERAL				
COLORS-WATER		130	141	11'
GRAVEL-BR. CLAY		141	150	9

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 150 feet  
Casing record 8  
Weight per foot 22.36 Thickness 1

Diameter	From	To
8 BLANK inches	0	130
8 Perf inches	130	150
_____ inches	_____	_____

Surface seal: Yes  No  Type concrete  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
Type perforation MILL SLOT  
Size perforation 1/8  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 12 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name HUMBOLDT DRILLING & PUMP CO., INC.  
P.O. 592 Contractor  
Address WINNEMUCCA, NEV. 89445  
Contractor  
Nevada contractor's license number 015234  
Nevada contractor's drillers number 961 C-23  
Nevada driller's license number 961  
Actual Driller  
Signed [Signature] Contractor  
Date 7-8-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours