WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24722
Permit No. DOMESTIC
Basin CARSON V. (8-105)
2429

1. OWNER Dorothy Atchison ADDRESS 180 Mills St Genoa

2. LOCATION E½ ¼ SE ¼ Sec. Sec 9 T. 13N N/S R. 19 E. Douglas County
PERMIT NO. SE¼ of NE¼ - Lot 5-6-7-8

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders-clay		0	45	45
Boulders		44	55	10
Rock-clay-boulders		55	75	20
1st water course	15	75	90	15
blue granite		90	125	35

1 HP Finet Walling (AIR Motor)
Set At 120 ft

Date started 7-15, 19 82
Date completed 7-31, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 125 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 inches	1 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Ready Mix
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 125 feet

Perforations:
Type perforation Torch
Size perforation
From 120 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 65
Flow G.P.M. 20
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MARCIO & SONS Drilling
Address 4340 Hwy 50 E
Nevada contractor's license number 18884
Nevada driller's license number 707
Signed Anthony Marcio
Date 9-8-82

USE ADDITIONAL SHEETS IF NECESSARY

5471