

Field check - 10/11/82 - R.M. + H.R.  
Address - 24724 APN = 47-030-13

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY NITE19-10A200

Please complete this form in its entirety

NOTICE OF INTENT NO. 2349

1. OWNER DOUG RASMUSSEN ADDRESS AT WELL LOCATION 17225 Big Pine Drive  
MAILING ADDRESS P.O. BOX 18554 GALENA CREEK AREA  
RENO, NV. 89511  
2. LOCATION SW 1/4 NE 1/4 Sec 10 T 17 N/S R. 19 E WASHOE County  
PERMIT NO. 45-261-03 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other  AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	4	4
Scattered boulders & D.G.		4	180	176
D&G Coarse gravels, Brown Clay Stringers		180	250	70
Piriatess- Felspars--some quartz		250	275	25
Red-brown volcanic rock-harder		275	392	117
Red & brown volcanic rock, with some clays-softer		392	421	29
Hard black rock layer		421	433	12
Volcanic rock-brown-red & Yellow-coarse sands-Multi-colored, with some clays tan in color		433	465	32

There is a 6' blank on bottom of casing string to aid in development.

8. WELL CONSTRUCTION  
Diameter hole 8 inches Total depth 464 feet  
Casing record 6 5/8  
Weight per foot 10.78 Thickness .156  
Diameter 6 5/8 inches From +18" feet To 464 feet  
Surface seal: Yes  No  Type Grout  
Depth of seal 55 feet  
Gravel packed: Yes  No   
Gravel packed from 464 feet to 55 feet  
Perforations:  
Type perforation Factory  
Size perforation 3/32 X 3  
From 436 feet to 458 feet  
From 436 feet to 458 feet  
From 436 feet to 458 feet  
From 436 feet to 458 feet

Date started 7-6, 19 83  
Date completed 7-11, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well at 250#--6000PM--for 1 1/2 hours to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
Static water level 160 feet below land surface  
Flow 8 G.P.M. P.S.I.  
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name AQUA DRILLING & WELL SERVICE, INC. Contractor  
Address 2255 GLENDALE AVE. - SPARKS, NV. 89431 Contractor  
Nevada contractor's license number 15291  
Nevada contractor's drillers number 1132  
Nevada driller's license number 1132 Actual Driller  
Signed Roger M. Thrall Contractor  
Date 7/11/83