

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2139

1. OWNER Frank Boller & G. Torviken ADDRESS AT WELL LOCATION Junction NO
MAILING ADDRESS 7580 Young Circle Highways 225 & 226
Reno, NV 89511

2. LOCATION S.E. 1/4 NW 1/4 Sec 25 T. 38 N/S R. 57 E Elko County
PERMIT NO. 45181 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
~~Municipal~~ Commercial Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	3	3
Gravel		3	10	7
Cemented gravel		10	20	10
Sandy clay w/p thin streaks of water bearing sand or fine gravel		20	140	120
Gravel w/water clay		140	150	10
		150	154	
	T.D.	154		

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 158 feet
Casing record 1.56' 4" x 8 5/8
Weight per foot 16.94 Thickness .188

Diameter	From	To
inches	feet	feet

Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 154 feet

Perforations:
Type perforation mill slots & t-cut
Size perforation 1/8" x 3"
From _____ feet to _____ feet
From 60 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 12 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING Co. Contractor
Address 203 PINE ST. ELKO, NV 89801 Contractor
Nevada contractor's license number 10819
Nevada contractor's drillers number 632
Nevada driller's license number 1302 Actual Driller
Signed James V. Muth Contractor
Date 7/11/83

Date started 6/14, 1983
Date completed 6/20, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 50 Draw down 7.5 feet 2 1/2 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours