

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2140

1. OWNER John W. Oldham ADDRESS AT WELL LOCATION Fox Springs Ranch
 MAILING ADDRESS 198 Walnut
Elko, NV 89801

2. LOCATION NW 1/4 SE 1/4 Sec. 28 T. 38 N/S R. 54 E Elko County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation
 Municipal Industrial

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Clay & gravel</u>		<u>3</u>	<u>10</u>	<u>7</u>
<u>Boulders</u>		<u>10</u>	<u>15</u>	<u>5</u>
<u>Sand, gravel, clay</u>		<u>15</u>	<u>60</u>	<u>45</u>
<u>streaks of sand & gravel, separated by clay</u>		<u>60</u>	<u>120</u>	<u>60</u>
		<u>T.D</u>	<u>120</u>	

8. WELL CONSTRUCTION

Diameter hole 10-8 inches Total depth 120 feet
 Casing record 121'4"
 Weight per foot 10.97 Thickness 200

Diameter	From	To
<u>10-8</u> inches		
<u>6-5/8</u> inches	<u>+ 1'4"</u>	<u>120</u>

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to T.D feet

Perforations:
 Type perforation Torch out
 Size perforation 1/8 x 6'

From _____ feet to _____ feet
 From 60 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 8 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING CO.
 Contractor

Address 203 Pine St., Elko, NV 89801
 Contractor

Nevada contractor's license number 10819
 Nevada contractor's drillers number 632
 Nevada driller's license number 1202
 Actual Driller

Date started 6/22, 1983
 Date completed 6/27, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed James V. Muth
 Contractor

Date 7/11/83