WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24730
Permit No. 42512
Basin 163

in Book

0339

(SANDY VALLEY ASSOCIATES)

1. OWNER Sky Ranche Estates ADDRESS Box 456 JEAN NV 89019

2. LOCATION NE ½ SE ¼ Sec. 6 T. 25 N/S R. 57 E. CLARK County
PERMIT NO. 42512

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Brkn Coral & Clay		4	12	8
White Clay	28	12	28	16
Hard Coral		28	32	4
Brn Sand & Clay		32	41	9
Brn Clay & Gravel		41	56	15
Brn ~~Clay~~ Caliche		56	59	3
Hard Brn Clay	Water	59	72	13
Brn Caliche	Water	72	78	6
White Clay		78	87	9
Caliche	Water	87	89	2
White Clay		89	91	2
Coral	Water	91	96	5
Brn Clay		96	97	1
Coral	Water	97	111	14
Clay		111	113	2
Caliche		113	126	13
LT Brn Clay		126	142	16
Hard Clay		142	151	9
Brn Clay		151	160	9
Caliche	Water	160	169	9
Brn Clay		169	200	31
Caliche	Water	200	216	16
LT Brn Clay		216	218	2
Caliche	Water	218	221	3
Clay & Brkn Caliche		221	250	29

Date started Dec 14, 1982
Date completed Mar 8, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
30 HP	400	152	12 HRS

RECEIVED
JUN 22 1983
Div. of Water Resources
Branch Office—Las Vegas, Nev.

BAILER TEST
G.P.M. 30 Draw down 3 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 14 inches Total depth 250 feet
Casing record 10"
Weight per foot 27.50 Thickness 3/16"

Diameter	From	To
10 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation Flame Cut
Size perforation 1/8 X 6"
From 60 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 Feet below land surface 22
Flow 400 G.P.M.
Water temperature 66° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Robert Spurlock
Address
Nevada contractor's license number 13264
Nevada driller's license number 1352
Signed Bill Ray Blood
1610 E LA MADRE WAY L.V. Nev
Date

5471

USE ADDITIONAL SHEETS IF NECESSARY