WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 24739
Permit No. DOMESTIC
Basin COLD SPRINGS V. (7-100)

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

FIELD CHECKED 21/18- 20bbdd 2

NOTICE OF INTENT NO. 2531 C

1. OWNER DELBERT JAMES
MAILING ADDRESS 1560 GLEN AYLSA AVENUE
EAGLE ROCK, L.A., CA. 90041

ADDRESS AT WELL LOCATION parcel 087-042-09
18905 PINION DRIVE
RENO, NV 89506

2. LOCATION NW ¼ NW ¼ Sec. 20 T 21 N/S R. 18 E WASHOE County
PERMIT NO. (Issued by Water Resources) | Parcel No. 087-042--09 | Subdivision Name COLD SPRINGS

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fine brown silt		0	2	2
light brown sandy clay w/gravel to 3/4"		2	29	27
some cobbles		29	34	5
tan sandy clay w/gravel		34	48	14
sand & gravel		48	52	4
layers of sand & gravel & soft sandy clay 2' to 3' thick	xx	52	154	102

Date started June 13, 1983
Date completed June 21, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 50-60 Draw down 40 feet 6 hours
G.P.M. 25 stable Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 154 feet
Casing record 8 5/8"od x .188 wall
Weight per foot 16.94 Thickness

Diameter	From	To
bore 12¼ inches	feet	feet
8 5/8 inches	+1 feet	154 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 154 feet

Perforations:
Type perforation milled
Size perforation 3" x 1/8"
From 109½ feet to 154 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 9 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SAGE BROS DRILLING COMPANY, INC. (Contractor)
Address 7800 N. VIRGINIA ST. RENO, NV 89506 (Contractor)
Nevada contractor's license number 7462A
Nevada contractor's drillers number 774 Harold Sage
Nevada driller's license number 953 Darby Cohen (Actual Driller)
Signed H. S. Sage (Contractor)
Date June 30, 1983

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434