WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

752-3205 REYNOLDS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24750
Permit No. DOMESTIC
Basin (A-49) DIXIE CREEK
TENMILE

1. OWNER Wells Propane ADDRESS ~~[illegible]~~ ON SPRING CREEK HWY

2. LOCATION NW ¼ NE ¼ Sec. 14 T. 33 N/S R. 56 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ RK

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	8	
Loose gravel		8	18	
Sandy clay		18	25	
Sand	X	25	29	
Brown clay		29	37	
Cemented Gravel	X	37	78	
Soft clay		78	87	
Thin sand clay layers		87	100	
Fine sand	X	100	125	
Coarse sand	X	125	145	

Date started 7/13, 1983
Date completed 7/14, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AIR ~~BAILER~~ TEST
G.P.M. 20+ Draw down 20 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 143 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
6" inches	71 feet	143 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Grout
Depth of seal 50 71 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from 55 feet to 143 feet

Perforations:
Type perforation Factory milled
Size perforation
From 123 feet to 143 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 Feet below land surface 22
Flow G.P.M.
Water temperature cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds
Address Wells, Nevada
Nevada contractor's license number C14410
Nevada driller's license number 115
Signed [illegible]
Date 7-22-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627