

OFFICE USE ONLY
 Log No. 24787
 Permit No. 40781
 Basin CANON RESERVOIR B-101

WELL DRILLERS REPORT

NOTICE OF INTENT NO. 1

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER Lacane Mining Inc. ADDRESS AT WELL LOCATION Packard Flat,
940 Matley Lane, Suite 10 Rochester Mining District
Reno, Nevada 89504

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T. 27N. N/S R. 34 E. Persing County
 PERMIT NO. 40781
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Gravel		0	15	15
Silty Sand & Gravel		15	42	27
Clay & Gravel		42	51	9
Part. Weathered Shale		51	160	109
Black Shale		160	210	50
Broken rock & gravel		210	249	39
Brown part. weathered shale		249	276	27
Black part. weathered shale		276	300	24
HOLE PLUGGED FROM 252 to 300 ft.				

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 300 feet
 Casing record
 Weight per foot Thickness .188 & .156

Diameter	From	To
<u>6</u> inches	<u>+2</u> feet	<u>252'6"</u> feet
.....inchesfeetfeet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 249 feet

Perforations:
 Type perforation Factory slot
 Size perforation 1/8 x 2 36 per ft.
 From (.188) 150 feet to 252'6" feet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Flow G.P.M. P.S.I.
 Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HACKWORTH DRILLING, INC.
 Contractor
 Address P. O. Box 850, Elko, NV 89801
 Contractor
 Nevada contractor's license number 20582
 Nevada contractor's drillers number 1166
 Nevada driller's license number 1231
 Actual Driller
 Signed Carl Zant
 Contractor
 Date

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>BLOW TEST</u>	<u>80</u>		<u>2 hrs.</u>

BAILER TEST

G.P.M. Draw downfeethours
 G.P.M. Draw downfeethours
 G.P.M. Draw downfeethours