

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2580

1. OWNER PYRAMID LAKE PAIUTE TRIBE ADDRESS AT WELL LOCATION I 80 SMOKE SHOP
 MAILING ADDRESS P.O. BOX 256 WADSWORTH, NV.
Nixon, NV. 89424

2. LOCATION NE 1/4 NE 1/4 Sec. 8 T. 20 N/S R. 24 E WASMOE County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden-fine sand with some clays		0	18	18
Volcanic sands & scattered rock		18	59	41
Hard volcanic Rock		59	94	35
Soft Fine sands		94	100	6
Volcanic Sands		100	128	28
Volcanic Rock-hard fractured red-green-black, some white & yellow chips		128	163	35
T.D. 163 ft.				

8. 10"-56" WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 163 feet
 Casing record 6 5/8"
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+3'</u> feet	<u>163</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 163 feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From _____ feet to _____ feet
 From 143 feet to 163 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 8-12, 1983
 Date completed 8-16, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well at 175 p.s.i. - 600 CFM for 2 hours to clean & develop			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL
 Static water level 68 feet below land surface
 Flow 14 G.P.M. P.S.I. _____
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE, INC. Contractor
 Address 2255 GLENDALE AVE. - SPARKS, NV. 89431 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 8-16-83