WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24815
Permit No. DOMESTIC
Basin FR. MEADOWS. 6-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER JOHN McCULLOCH
MAILING ADDRESS 1275 SWEETWATER DR
RENO
ADDRESS AT WELL LOCATION

2. LOCATION S½ ¼ NE ¼ Sec. 26 T. 19 N/S R. 19 E County
PERMIT NO. (Issued by Water Resources) C23 490-17 (Parcel No.) BK 24-05 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Hot
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Yellow Sandy Clay | | 0 | 75 | 75 |
| Sand & Gravel | X | 75 | 80 | 5 |
| Blue Sandy Clay | | 80 | 173 | 93 |
| Sand & Gravel | | 173 | 178 | 5 |
| Blue Clay | | 178 | 248 | 70 |
| Gravel & Rock | | 248 | 290 | 42 |
| Blue Shale | | 290 | 310 | 20 |
| w/ yellow shale | | | | |

Date started ....., 19....
Date completed ....., 19....

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 15+ Draw down 0 feet ½ hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 310 feet
Casing record 0-310
Weight per foot ..... Thickness 180

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 80 feet |
| 8 inches | 80 feet | 310 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 0-80 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Saw Slot
Size perforation 3/32 x 2½
From 240 feet to 310 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 80 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER (Contractor)
Address 690 STARLIGHT CIR RENO (Contractor)
Nevada contractor's license number 14170
Nevada contractor's drillers number 514
Nevada driller's license number 718
Signed Edmund Miller (Actual Driller)
Date Aug 17 1983 (Contractor)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434