WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 24821
Permit No. Domestic
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

WHERE?

1. OWNER J. Sterling ADDRESS V+T Rd - Mark Twain

2. LOCATION SW ¼ ¼ Sec. 27 T. 17N N/S R. 21 E. 7 Lyons County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		1	2	2
Hard pan		2	35	33
Cemented Granite		35	60	25
1st water		60	65	5
Cemented granite		65	75	10
Cemented sand		75	95	20
2d water		95	100	5
Cemented sand		100	115	15
3d water		115	120	5
Cemented sand		120	130	10
4d water		130	135	5
Cemented Gravel		135	150	15

Date started ≈ July 9, 1983
Date completed, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 150 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 inches	1 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Ready Mix
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Louvre
Size perforation 1/8 x 4" - 5 Rows
From 5 feet to 53 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 55 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Marcin & Sons Drilling
Address 4340 Hwy 50E
Nevada contractor's license number 18884
Nevada driller's license number 707
Signed Thelma Marcin
Date 7-23-83

USE ADDITIONAL SHEETS IF NECESSARY