WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 24822
Permit No. 04092
Basin LEMMON V. 7-92(B)

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Rick Ly May ADDRESS North Virginia St
Foothill Trailer Court
430 Stoker Ave Reno

2. LOCATION NW ¼ SW ¼ Sec. 8 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. C.O.

3. TYPE OF WORK (Vested Right)
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Commercial
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dark Brown top soil		0	2	2
yellow clay w/ rocks		2	71	69
large (course) gravel		71	76	5
sandy clay		76	123	47
Weathered Vol. Rock		123	135	12
medium hard Volcanic Rock		135	249	114
Decayed granite		249	267	18
Hard granite		268	294	26
medium hard granite w/ intermitten fractures	X	294	319	25
fractured (open) granite	X	319	326	
medium hard granite rock		326	337	

Date started 8-1, 1983
Date completed 8-3, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 6 feet
Casing record
Weight per foot ..... Thickness 1156

Diameter	From	To
6 5/8 Sch. inches	0 feet	337 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 260 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 260 feet to 337 feet

Perforations:
Type perforation factory slotted
Size perforation 3/32 & 2½
From ..... feet to ..... feet
From 270 feet to 337 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 150 Feet below land surface
Flow ..... G.P.M. Approx. 25
Water temperature Cold ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 So. Patterson, Sparks Nev.
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul E Williams
Date 8-3-83

USE ADDITIONAL SHEETS IF NECESSARY

U-627

'83 AUG 24 A10:20

STATE ENGINEER'S OFFICE