WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24830
Permit No. 27714
Basin TR. MEADOWS 6-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER TRUCKEE PARK (MOBILE HOME PARK)
MAILING ADDRESS 7360 W. 4th ST. #2 RENO, NEV. 89523
ADDRESS AT WELL LOCATION 7360 W. 4th St. (NEAR PUMP HOUSE) RENO, NEV. 89523

2. LOCATION NE ¼ SE ¼ Sec. 18 T. 19 N/S R. 19 E WASHOE County
PERMIT NO. 27714 (Issued by Water Resources) REPLACEMENT WELL (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	5	5
Clay and Rock		5	25	20
Black Sand + Gravel		25	35	10
Shale Rock & Sandclay		35	55	20
Black Sand & Rock		55	75	20
Black Clay		75	115	40
Brown clay		115	375	260
Clay with Sand		375	475	100
Clay		475	535	60
Clay with Sand		535	668	133

Replacement of log # 22084

Date started JULY 14, 19 83
Date completed August 22, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
JET TEST	60	320	6 HOURS

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 13 inches Total depth 668 feet
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
6 5/8 inches	-0- feet	668 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 176 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 176 feet to 668 feet

Perforations:
Type perforation 1/8 FACTORY SLOT
Size perforation
From 337 feet to 444 feet
From 464-484 feet to 504-524 feet
From 544-564 feet to 584-604 feet
From 624-644 feet to feet
From feet to feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Brinkerhoff (Contractor)
Address 7360 W 4th street (Contractor)
Nevada contractor's license number 20578
Nevada contractor's drillers number 1161
Nevada driller's license number 730 (Actual Driller)
Signed ..... (Contractor)
Date AUGUST 22, 1983

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434