WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24835
Permit No. TO BE PLUGGED
Basin ELKO SEC. 4-49
NO INTENT CARD

1. OWNER Fremont Const ADDRESS Las Vegas Nev

2. LOCATION N W ¼ ~~SW~~ N.E. ¼ Sec. 1 T. 34 N/S R. 55 E. Elko County
PERMIT NO. Non-Consumptive

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Non-Consumptive
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	4	4
Brown Clay		4	128	124
Blue Clay		128	221	93
Yellow Clay & gravel		221	254	32

Date started 8-24-, 1983
Date completed 8-25, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 254 feet
Casing record 255
Weight per foot 10.56 Thickness .156

Diameter	From	To
10 inches	0 feet	50 feet
8 inches	50 feet	254 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: ~~Yes~~ ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: ~~Yes~~ ☒ No ☐
Gravel packed from 254 feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 1/8 x 2
From 254 feet to 234 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 74 Feet below land surface
Flow No G.P.M. 60
Water temperature Cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A-1 Western Drilling
Address Box 1826 Elko, Nev
Nevada contractor's license number 015356
Nevada driller's license number 1072
Signed B B Bailey
Date 8-26-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627