WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24852
Permit No. DOMESTIC
Basin I.R. MENDOWS 10-87

1. OWNER Norm Snow ADDRESS 1880 MANZANITA

2. LOCATION NE ¼ NW ¼ Sec. 26 T. 19 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. HOT PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Yellow Sandy Clay		0	67	67
Sand & Gravel	X	67	72	5
Yellow Sandy Clay		72	138	66
Blue Sandy Clay		138	250	112
Grey Sandy Clay		250	275	25
Blue Sharp Rocks	X	275	277	2
Grey Sandy Clay		277	320	43
Rock		320	322	2
Grey Sandy Clay		322	382	60
Hard Shale Rock	X	382	415	33

Date started Aug 18, 19 83
Date completed Aug 25, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15+ Draw down 0 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 415 feet
Casing record 0 - 415
Weight per foot Thickness 188

Diameter	From	To
12 inches	0 feet	80 feet
8 inches	80 feet	415 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 0 - 80 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Saw Slot
Size perforation 3/32 x 2½
From 368 feet to 415 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 43 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Edmund Miller
Address Box 92 Smith, NV
Nevada contractor's license number 12272
Nevada driller's license number 718
Signed Edmund Miller
Date 9-2-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627