WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24854
Permit No. DOMESTIC
Basin

1. OWNER John C. Fuerst ADDRESS 10465 S. Grassvalley Rd. Winne., Nev
GRASSVALLEY ESTATES

2. LOCATION E. ½ ¼ E. ½ ¼ Sec. 36 T. 35 N. N/S R. 38 E/W Humboldt County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
soil brown		0'	2'	2'
sandy;clay brown		2'	9'	7'
gravel brown		9'	15'	6'
gravely clay brown		15'	65'	50'
sandy;clay brown		65'	84'	19'
clay with strips of sand & gravel brown	36'	84'	120'	

Date started August 9, 19 83
Date completed August 15, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 35 Draw down 20 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 120' feet
Casing record 120' .156 wall
Weight per foot 11 lbs. Thickness .156

Diameter	From	To
6" inches	0 feet	120' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cemente
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation tourch
Size perforation 1/8" by 4"
From 88' feet to 118' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60' Feet below land surface
Flow good G.P.M. 35
Water temperature 54 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Tom Stites
Address 9015 S. Grassvalley Rd. Winne. Nev.
Nevada contractor's license number 017721
Nevada driller's license number 1190
Signed Tom Stites
Date Sept. 6 1983

USE ADDITIONAL SHEETS IF NECESSARY

O-627