WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

EXIST WELL [illegible]

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24859
Permit No. DOMESTIC
Basin CHURCHILL V. 3-102

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Thomas A Fiorica
MAILING ADDRESS P.O. Box 14
Silver Springs, NV. 89429

ADDRESS AT WELL LOCATION 3205 Citrus St.
Silver Springs, NV.

2. LOCATION ¼ ¼ Sec. 25 T. 18 N N/S R. 24E E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	4	4
Clay		4	23	19
Sand & Clay		23	44	21
Sand & Gravel		44	47	3
Sand & Clay		47	68	21
Sand & Gravel		68	74	6
Gravel	✓	74	87	13
Clay		87	89	2
Sand		89	118	29
Gravel		118	153	35

Existing Well
Plugged Concrete

Date started 8-22, 1983
Date completed 8-25, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 153 feet
Casing record 8 5/8" x 1.88 wall
Weight per-foot 169 Thickness 188

Diameter	From	To
12" Hole inches	0 feet	50 feet
8 inches	50 feet	153 feet
inches	feet	feet
Casing inches	feet	feet
8 5/8 inches	feet	feet
inches	0 feet	153 feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation ~~20 of 1/32~~ Factory
Size perforation 3/32
From 133 feet to 153 WP feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 62' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F. Quality Unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Pump & Drilling Co. (Contractor)
Address P.O. Box 4088 - C.C. NV. (Contractor)
Nevada contractor's license number 012236B
Nevada contractor's drillers number 1393
Nevada driller's license number 1394 (Actual Driller)
Signed Curtis Bludsworth (Contractor)
Date 8-18-83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434