

WELL DRILLERS REPORT

NOTICE OF INTENT NO. 1004

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER RALPH GONZALES ADDRESS AT WELL LOCATION PILOT VALLEY AREA
 MAILING ADDRESS BOX 101 WENDOVER, UTAH 89083

2. LOCATION NE 1/4 NE 1/4 Sec. 33 T. 38 N. R. 69 E. ELKO County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	3	3
HARD PAN		3	17	17
GRAVEL		20	38	18
CLAY (LIGHT)		38	235	197
SAND & CLAY		235	240	5
CLAY (LIGHT)		240	268	28
SAND & GRAVEL		268	330	62
CLAY (GRAY)		330	335	5

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 335 feet
 Casing record 8 7/8
 Weight per foot _____ Thickness 12 1/8

Diameter	From	To
<u>8 7/8</u> inches	<u>335</u> feet	<u>0</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 60 FT feet
 Gravel packed: Yes No
 Gravel packed from 335 feet to 60 feet

Perforations:
 Type perforation FACTORY
 Size perforation 1/8 INCH
 From 335 feet to 240 feet
 From _____ feet to _____ feet

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3400</u>	<u>22</u>	<u>5</u>	<u>10</u>

9. WATER LEVEL
 Static water level 65 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MARK HALLMARK Contractor
 Address Box 473 - Pioche, NV Contractor
 Nevada contractor's license number _____
 Nevada contractor's drillers number 1333
 Nevada driller's license number 1333 Actual Driller
 Signed Clyde R. Hallmark Contractor
 Date 8-6-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3400</u>	<u>22</u>	<u>5</u>	<u>10</u>

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____