WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 24880
Permit No. 41413
Basin

WELL DRILLERS REPORT

PRINT OR TYPE ONLY Sha-Nova Inc
Please complete this form in its entirety

NOTICE OF INTENT NO. 3322

1. OWNER Patrick Shane
MAILING ADDRESS 11497 Lemon Dr. Reno, Nev. Waiver #W-040
ADDRESS AT WELL LOCATION North of Mustang exit off interstate 80 No address

2. LOCATION N ¼ NE ¼ NW ¼ Sec. 16 T. 19 N/S R. 21 E Washoe County
PERMIT NO. 41413 OK (Issued by Water Resources) 84-060-14 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☑

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White soft Rock		0	103	103
Med Hard Brown Val. Rock (solid)		103	210	107
Med hard grey Val.		210	235	25
Hard Brown Val. Rock		235	265	30
fractured grey Valc. Rock		265	276	11
Hard grey Rock		276	283	7
fractured grey Val. Rock		283	310	27
soft grey Rock		310	345	35
fractured Val. Rock		345	361	16
soft grey Rock		361	380	19
soft red Val. Rock		380	429	49
fractured Red Valc. Rock		429	439	10
fractured grey Val. Rock		439	445	06
med. Hard Red Rock	X	445	490	45
fractured Red Rock	X	490	515	25
large fractures or Fault Zone	XXX	515	528	13

See Log # 26296 for deepening #

Date started 9-1, 1983
Date completed 9-3, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 od inches Total depth 528 feet
Casing record
Weight per foot 16.90 Thickness .188

Diameter	From	To
8 5/8 od inches	0 feet	528 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & cement grout
Depth of seal 60 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory sawed
Size perforation 3.32 x 2½" (double Row)
From ..... feet to ..... feet
From 506 feet to 528 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level approx. 370 feet below land surface
Flow approx. 300 G.P.M. ..... P.S.I.
Water temperature warm F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons. (Contractor)
Address Patterson Pl. 22. Sparks Nev. (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957 (Actual Driller)
Signed Paul E Williams (Contractor)
Date 9-9-83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434