

WELL DRILLERS REPORT

Please complete this form in its entirety.

NOTICE OF INTENT NO 2775

PRINT OR TYPE ONLY

1. OWNER John Sweett ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 1055 Thomas Cir. Reno

2. LOCATION S. 1/4 S. 40 T. 18 N/S R. 20 E Washoe County  
 PERMIT NO. 30-310-44 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sandy clay		0	4	
large gravel		4	12	
sandy gravel		17	91	
sand		91	115	
gravel	X	115	140	

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 140 feet  
 Casing record  
 Weight per foot 9 Thickness 156  
 Diameter From To  
6 3/8 inches 0 feet 140 feet  
 Surface seal: Yes  No  Type pumped gravel  
 Depth of seal 60 feet  
 Gravel packed: Yes  No   
 Gravel packed from 60 feet to 140 feet  
 Perforations:  
 Type perforation factory sealed  
 Size perforation 3 3/32 x 2 1/2  
 From 119 feet to 140 feet

9. WATER LEVEL

Static water level approx. 10 feet below land surface  
 Flow approx. 90 G.P.M. P.S.I.  
 Water temperature cool ° F. Quality clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Paul Williams & Sons Contractor  
 Address 22 So. Pullman, Sparks, Nev. Contractor  
 Nevada contractor's license number 14483  
 Nevada contractor's drillers number 957  
 Nevada driller's license number 957  
 Signed Paul Williams Actual Driller  
 Date 8-30-83 Contractor

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours