WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 7A907
Permit No. DOMESTIC (RE-COND)
Basin TRUCKEE MEADOWS 6-87

NOTICE OF INTENT NO. 2592

1. OWNER LARRY EIGENMAN
MAILING ADDRESS 5665 MT. ROSE HWY
RENO, NEVADA 89511

ADDRESS AT WELL LOCATION 5665 MT. ROSE HWY
RENO, NV.

2. LOCATION SE ¼ SE ¼ Sec. 26 T. 18 N/S R. 19 E WASHOE County
PERMIT NO. (Issued by Water Resources) 045-032-34 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☒
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
4" Liner is down to 178 ft., and has Rocks and Sands in Borehole at Bottom				
This Well is supposed to be 225 ft. deep. Past drilling was done with Cable Tool and 6" Casing was run to approximately 180 ft. then a 4" Liner was to be placed to T.D., but it is not.				

Date started 9-21, 1983
Date completed 9-21, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Tripped in and blew well for 1½ hours at 178'. Would not clean up.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth ..... feet
Casing record .....
Weight per foot ..... Thickness .....

Diameter	From	To
6 inches	1 feet	138 feet
inches	feet	feet
4 inches	138 feet	178 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation .....
Size perforation .....
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 166 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AQUA DRILLING & WELL SERVICE, INC. (Contractor)
Address 2255 GLENDALE AVE. - SPARKS, NV. 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132
Signed Roger M. Thrall (Actual Driller)
Roger M. Thrall (Contractor)
Date 9-21-83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434