

SEC 36 bdac

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2446

1. OWNER Dean Smith ADDRESS AT WELL LOCATION Duck Hill
 MAILING ADDRESS 6155 Lakside Dr Reno NV PA # 55-320-28 (no address)

2. LOCATION SE 1/4 NW 1/4 Sec 36 T 16 N/S R 19 E Washoe County
 PERMIT NO. 1999 CO. Washoe PA # 55-320-28
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G.		0	3	3
Weathered broken granite		3	45	42
hard solid granite		42	437	395
soft granite		437	442	05
fractured granite	X	442	449	7
hard granite		449	455	6

8. WELL CONSTRUCTION

Diameter hole 6 7/8 inches Total depth 455 feet
 Casing record
 Weight per foot 7 Thickness 156

Diameter	From	To
<u>6 7/8</u> inches	0	397

Surface seal: Yes No Type Cement grout
 Depth of seal 62 feet
 Gravel packed: Yes No
 Gravel packed from 62 feet to 455 feet

Perforations:
 Type perforation fractured sand
 Size perforation 3-32 X 2 1/2

From 397 feet to 455 feet

9. WATER LEVEL

Static water level 325 feet below land surface
 Flow 60 G.P.M. P.S.I.
 Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Williams & Sons
 Address 22 So Patterson Pl Sparks NV
 Nevada contractor's license number 14483
 Nevada contractor's drillers number 957
 Nevada driller's license number 957
 Signed Paul E. Williams Contractor
 Date 9-22-83

Date started 9-20 1983
 Date completed 9-22 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours