WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

I

OFFICE USE ONLY
Log No. 24926
Permit No. DOMESTIC
Basin TRUCKEE MEADOWS 6-87

PRINT OR TYPE ONLY
Please complete this form in its entirety

NOTICE OF INTENT NO. 3304

1. OWNER Robert Ritter Duane Moore
MAILING ADDRESS 6155 Lakeside Dr. Reno Nev.
ADDRESS AT WELL LOCATION 35 Baragry Way Mt. Rose Highway

2. LOCATION SW 5 ¼ SE ¼ Sec. 30 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. Washoe Co. 2004 (Issued by Water Resources) | 45-200-12NV3 (Parcel No.) | APN ~~44-251-03~~ (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand gravel + boulders with clay Binder		0	163	163
sandy clay		163	324	161
Cemented Sand		324	370	46
Sandy clay D.G.		370	469	99
Med. hard Vol. Rock		469	478	9
Hard grey Rock		478	512	34
fractured grey Rock	X	512	526	14
N 39,390657				
W 119,776164 NAD27				
Plugged under NOI 61163				

Date started 9-24, 1983
Date completed 9-27, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10" 48 3/4 inches Total depth 526 feet
Casing record
Weight per foot 6.3 Thickness .156

Diameter	From	To
6 5/8 o.d. inches	0 feet	488 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & Cement
Depth of seal 65 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 65 feet to 526 feet

Perforations:
Type perforation factory Sawed
Size perforation 3-32 x 2 1/2
From ..... feet to ..... feet
From 488 feet to 526 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level approx. 360 feet below land surface
Flow approx. 12 G.P.M. ..... P.S.I.
Water temperature 110 °F. Quality unkone

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons (Contractor)
Address 22 So. Patterson Sparks Nev. (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957 (Actual Driller)
Signed Paul E. Williams (Contractor)
Date 9-27-83

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY O-627 CR434