WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24931
Permit No.
Basin 162

Book 1

1. OWNER Jim Laute ADDRESS Pahrump Hwy 160

2. LOCATION SE ¼ NW ¼ Sec 24 T. 20 N/S R. 53 E County
PERMIT NO. 36808

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Deepen Well from 20'				
Sand Gravel Boulders		20	80	60
Red Clay		80	100	20
Hard rock		100	140	40
Fractured Rock	X	140	150	10

RECEIVED
AUG 22 1983
Div. of Water Resources
Branch Office — Las Vegas, Nev

Date started 6-1-, 19 83
Date completed 6-8, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 150' feet
Casing record 8 5/8 X 150
Weight per foot 15.76 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 6" 2 Rows
From 110 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 92 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Custom Drilling Inc
Address 4425 Stacey Ave
Nevada contractor's license number 19219
Nevada driller's license number 1081
Signed [illegible]
Date 6-30-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627