WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25019
Permit No. DOMESTIC
Basin TR. MEADOWS 6-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3656

1. OWNER BOB WALTS GLEN MOLLEY
MAILING ADDRESS 884 ~~Gilomolley~~ DR.
Sparks, NV 89431

ADDRESS AT WELL LOCATION 2660 WESTVIEW DR
0.25 MI. N. OF SPARKS FAMILY HOSPITAL

2. LOCATION SW ¼ NE ¼ Sec. 01 T. 19N N/S R. 20E Washoe County
PERMIT NO. (Issued by Water Resources) 30183-01 (Parcel No.) East Sparks (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown volcanic				
bolders cemented				
with brown clay		0	40	40
Black volcanic rock		40	110	70
Red volcanic rock		110	165	55
Brown & red sandy clay		165	177	12
Red volcanic rock		177	205	28
Black fracture rock	x	205	240	35
Black hard volcanic rock		240	250	10
Water Strata (205-240)				

Date started 10-27-83, 19
Date completed 10-28-83, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 250 feet
Casing record 250
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 198 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 175 AIR BLOWN AT LEAST THIS AMOUNT. feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 14043
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed Gary C. Hedman (Contractor)
Date October 31, 1983

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434