WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25036
Permit No. DOMESTIC
Basin

1. OWNER John Van Fange ADDRESS 11465 Sage Reno Nev 89506

2. LOCATION NE ¼ SE ¼ Sec. 24 T. 21 N/S R. 18 E. WASHOE County
PERMIT NO. 7029 (WASHOE CO. HEALTH)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Hard pan		2	4	2
Fine Sand		4	25	21
Brown Clay w/ some sand		25	54	29
Fine to coarse sand w/ some brown clay		54	93	39
Brown clay		93	97	4
Fine to coarse sand w/ some clay	X	97	152	55

Date started 11-7, 19 83
Date completed 11-15, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 32 Draw down 15 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 152 feet
Casing record 8 5/8 O.D
Weight per foot Thickness .156

Diameter	From	To
8 5/8 O.D inches	4.1 feet	152 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 152 feet

Perforations:
Type perforation MILL
Size perforation 1/8 X 3
From 129 feet to 152 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 55 Feet below land surface
Flow G.P.M.
Water temperature Unknown ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE Drilling + Development
Address 10655 Stuart Wells Blvd Reno Nev 89506
Nevada contractor's license number 14799
Nevada driller's license number 726
Signed [illegible]
Date 11-18-1985

USE ADDITIONAL SHEETS IF NECESSARY

O-627