WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25071
Permit No.
Basin PLEASANT V 6-88

Well #1 47139
Water W121 47140

Intent 2508

1. OWNER Caesars Resort ADDRESS 1755 E. Plumb Lane STE 212 Reno Nev.

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 17 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Brown Clay & Rock		0	30	30
Boulders & Sandy Gravel		30	80	50
Boulders		80	100	20
Sandy Gray Clay & Rock		100	150	50
" " " "		150	190	40
Boulder		190	193	3
Granite		193	195	2
Granite		195	220	25
Clay & Volcanics		220	240	20
Clay		240	250	10
Boulder		250	252	2
Soft Formation Clay & Rock		252	280	28
Granite & Fractures		280	302	22
Loose Formation (Losing Mud)		302	360	58
Granite & Clay		360	370	10
Granite No Fractures		370	403	33
This well was Cased to 300 ft with 8 5/8 Then Sleeved from 300-403 with 6 5/8 Casing				
William North was Geologist on Job				
After Pump test of 72 Hr. well only pumped 30 gpm				

Date started 10/8, 19 83
Date completed 10/30, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	80	60	24 Hr.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12-7 7/8 inches Total depth 403 feet
Casing record 8 5/8 - 6 5/8
Weight per foot ..... Thickness 250-188

Diameter		From		To	
8 5/8	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 300 feet to 50' feet

Perforations:
Type perforation Factory
Size perforation 1/4 x 3 - 1/8 x 3
From 8" 220 feet to 240 feet
From 260 feet to 300 feet
From ..... feet to ..... feet
From 6" 300 feet to 403 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 340 Feet below land surface 60
Flow ..... G.P.M. 30
Water temperature Cold ° F. Quality —

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump & Drilling
Address Carson City
Nevada contractor's license number 012236
Nevada driller's license number 1001
Signed Cortus Blackworth by [illegible]
Date 12/27/83

USE ADDITIONAL SHEETS IF NECESSARY

O-627