WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25072
Permit No.
Basin PLEASANT V. 6-88
Intent 25096

Well #2
Water W 121 47139
47140

1. OWNER Galena Resort ADDRESS 1755 E Plumb Lane

2. LOCATION SE ¼ SW ¼ Sec. 18 T. 17 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Brown Clay		0	5	5
Sand + Gravel		5	18	13
Sand + Boulders		18	60	42
Boulders		60	160	100
Granite		160	180	20
Boulders + Granite		180	300	120
Granite [redacted] (water)		300	496	196

10" Pipe was cemented in to 30'
6 yrds Cement was used & pumped
in to contain flow

Then A 9 7/8 Hole was drilled to 301
& Cased with 8 5/8" Casing No perf.
were used

A 7 7/8 Hole was then drilled to
496'

Well was Flowing 40 gpm and can
be Contained

Date started 11/16, 1983
Date completed 12/20, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	200	100	16

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17" 10" 7 7/8 inches Total depth 496 feet
Casing record 8 5/8
Weight per foot ..... Thickness .250

Diameter	From	To
8 5/8 inches	0 feet	301 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 60' feet
Gravel packed: Yes ☐ No ☑
Gravel packed from — feet to — feet

Perforations:
Type perforation —
Size perforation —
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 496 Feet below land surface 0
Flow 40 G.P.M. 200
Water temperature Cold ° F. Quality —

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump & Drilling
Address Carson City
Nevada contractor's license number 012236
Nevada driller's license number 1001
Signed Curtis Blindsworth by [illegible]
Date 12/27/83

USE ADDITIONAL SHEETS IF NECESSARY

O-627