WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 2508/(see 2500a)
Permit No. Domestic
Basin 88

PRINT OR TYPE ONLY

CEBC

NOTICE OF INTENT NO. 3204

1. OWNER Gerald R. Flood
MAILING ADDRESS 960 Virbel Lane
Reno, Nv. 89502

ADDRESS AT WELL LOCATION FAWN LANE - MT. ROSE HWY.
RENO, NV.

2. LOCATION NW ¼ SW ¼ Sec. 36 T. 18 N/S R. 19 E WASHOE County
PERMIT NO. ____ Issued by Water Resources | 045-070-58 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	13	13
Granite, boulders, large gravels with clay lenses scattered throughout.		13	184	171
(First water strata) at	164			
T.D. 184'				
Org Plugged by 2509				
Replaces well unknown				
Deepend by log # 11668C				

Date started 1-4, 19 84
Date completed 1-6, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew Well for 2½ Hrs. at 150 PSI 600 CFM to clean and develop			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
10" for 55'
Diameter hole 8 inches Total depth 179 feet
Casing record 6 5/8" - .156
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+ 12" feet	179 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Grout
Depth of seal 54 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 54 feet to 179 feet

Perforations:
Type perforation Factory
Size perforation 3/32 X 3
From 161 feet to 179 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 90 feet below land surface
Flow 20+ G.P.M. ____ P.S.I.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AQUA DRILLING & WELL SERVICE, INC. (Contractor)
Address 2255 GLENDALE AVE. - SPARKS, NV. 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132
Signed Roger M. Thrall (Actual Driller)
Roger M. Thrall (Contractor)
Date 1-6-84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) D-627 CR434