WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25096
Permit No. DOMESTIC
Basin WARM SPR. V. 6-84

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. NO CARD

1. OWNER Bryan Yorkey
MAILING ADDRESS 6205 Lost Springs Road NE SE
ADDRESS AT WELL LOCATION Same
Palomino V. Unit 3 3-2-8-6

2. LOCATION portion ¼ E ½ ¼ Sec. 3 T 22 N/S R 20 E Washoe County
PERMIT NO. 2033 WASHOE HEALTH Issued by Water Resources
1936 Parcel No.
parcel 76-120-14 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	40	40
Red Clay & Sand		40	80	40
Sand & Clay		80	130	50
Sand & Gravel		130	180	50
Clay		180	200	20
Coarse Sand w/ Clay		200	239	39
Clay w/ some Sand		239	300	61
Coarse white Sand w/ intermillent Clay seams		300	480	180
Clay		480	495	15

Date started Nov. 16, 1983
Date completed Dec 20, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 82 inches Total depth 495 feet
Casing record 8
Weight per foot ..... Thickness 156

Diameter	From	To
8 inches	0 feet	495 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 60' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 495 feet

Perforations:
Type perforation Mill Slot
Size perforation 3/32 x 4 inch
From 420 feet to 480 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Alcove Drilling
Contractor
Address P.O. Box 139 Battle Mt NV 89820
Contractor
Nevada contractor's license number 20692
Nevada contractor's drillers number 20692
Nevada driller's license number 1221
Actual Driller
Signed William P. Allen
Contractor
Date Jan 3, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434