WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25099
Permit No. DOMESTIC
Basin DAYTON V. 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3632

1. OWNER Alex Ecko
MAILING ADDRESS 2903 Panament Rd
Carson City, NV 89701

ADDRESS AT WELL LOCATION

2. LOCATION ¼ ¼ Sec. 11 T. 17 N/S R. 23 E Lyon County
PERMIT NO. (Issued by Water Resources) | 3 Three (Parcel No.) | Rancho subdivision #2 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandie clay		0	30	30
Clay & Rock		30	70	40
Sandie clay		75	100	25
Clay & Rock		100	120	20

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 120 feet
Casing record 8 5/8
Weight per foot 16.9 Thickness 188

Diameter	From	To
8 inches	0 feet	100 feet
12 3/4 inches	0 feet	50 feet
8 inches	50 feet	120 feet
casing inches	feet	feet
8 5/8 inches	feet	feet
8 5/8 inches	0 feet	120 feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow -0- G.P.M. P.S.I.
Water temperature 0 °F. Quality Unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Pump & Drilling Inc (Contractor)
Address 4639 Hiway 50 E. Carson City (Contractor)
Nevada contractor's license number 012236B
Nevada contractor's drillers number 136
Nevada driller's license number 136 (Actual Driller)
Signed [signature] (Contractor)
Date 1-14-84

Date started 1-10, 19 84
Date completed 1-13, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 18 Draw down 15 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434