WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25127
Permit No. Domestic
Basin Quinn River V. 2-33

1. OWNER Nevada-Cal. Properties, Inc. ADDRESS Sky Haven Ranchette P.O. Box 164 Orvada, Nevada 84425

Lot 12 Block B

2. LOCATION ¼ W-½ ¼ Sec. 18 T. 42N N/S R. 37 E. Humboldt County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil sandy brown		0	2	2
Sand brown		2	43	41
Sand brown course		43	67	24
Sandy clay brown		67	80	13
Sand & gravel brown	W.B.	80	102	22

Date started January 17, 19 84
Date completed January 21, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 36 Draw down 10 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 100 feet
Casing record eight inch
Weight per foot 15 Thickness 156

Diameter	From	To
8 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch
Size perforation 4" by 1/8"
From 70 feet to 98 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface
Flow 36 G.P.M.
Water temperature 54 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T & R WELL DRILLING
Address 9015 S. Grassvalley, Winnemucca, N
Nevada contractor's license number 017721
Nevada driller's license number 1190
Signed Tom Stitz
Date January 30, 1984

USE ADDITIONAL SHEETS IF NECESSARY

O-627