

Log No. 25193  
 Permit No. DOMESTIC  
 Basin TRACY SEDIMENT 6-83

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2671 ✓

PRINT OR TYPE ONLY

1. OWNER AL LAMBERTI ADDRESS AT WELL LOCATION CANAL ROAD  
 MAILING ADDRESS P.O. BOX 1267  
sparks, Nevada 89431 PAINTED ROCK - EXIT 40 OFF HWY I-80  
 2. LOCATION SW  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 22 T. 20 N/S R. 23 E. STOREY County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
8" METAL CASING FROM THEN 8" OF A DRIVESHOE	- - - -	57	67	10
BLACK BASALT, WITH SCATTERED SOFTER ZONES		67	260	193
GRAY GREEN SOFT ROCK		260	270	10
SOFT BROWN ROCK		270	280	10
BLUE GREEN SEDIMENT		280	315	35
BLUE GREEN ROCK		315	400	85
T.D. 400 ft.				

8. WELL CONSTRUCTION  
 Diameter hole 7 7/8 inches Total depth 400 feet  
 Casing record 6 5/8 .156  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>60</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation FACTORY  
 Size perforation 3/32 X 3  
 From 160 feet to 180 feet  
 From 380 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Flow 2 1/2 G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cool ° F. Quality LITE GREEN COLOR

Date started 2-3, 1984  
 Date completed 2-6, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
BLEW WELL WITH AIR TO CLEAN AND DEVELOP			

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE, INC.  
 Contractor  
 Address 2255 GLENDALE AVE. - SPARKS, NV. 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M. Trall  
 ROGER M. TRALL Contractor  
 Date 2-6-84

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours