

Finalized mt Well # 4

Well Plugged - 6/25/84

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2760

1. OWNER Hebert Kromish Trust ADDRESS AT WELL LOCATION Lake Dr. & Bridge St Verdi, Nev.
 MAILING ADDRESS P.O. Box 950 Verdi, Nev.

2. LOCATION $\frac{1}{4}$ Sec. 7 T. 19 N/S R. 18 E. Washoe County
 PERMIT NO. 055-045-0251 Parcel No. Verdi Lake Estates Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation
 Municipal Industrial

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand gravel & Boulders</u>		<u>0</u>	<u>26</u>	
<u>grey clay</u>	<u>X</u>	<u>26</u>	<u>64</u>	
<u>brown clay</u>		<u>64</u>	<u>84</u>	
<u>sandy clay grey</u>	<u>X</u>	<u>84</u>	<u>96</u>	
<u>trucker formation</u>		<u>96</u>	<u>119</u>	
<u>solid black volcanic rock</u>	<u>X</u>	<u>119</u>	<u>125</u>	

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 125 feet
 Casing record _____
 Weight per foot 10 Thickness 15.6
 Diameter 6 7/8 inches From 0 feet To 125 feet
 _____ inches _____ feet _____ feet

Surface seal: Yes No Type sand & cement grout
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation factory sized
 Size perforation 3-32 x 2 1/2
 From _____ feet to _____ feet
 From 105 feet to 125 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level approx. 30 feet below land surface
 Flow approx. 40 G.P.M. P.S.I.
 Water temperature 60 ° F. Quality unknown

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Williams & Sons
 Address 22 So. Patterson, Sparks
 Nevada contractor's license number 14483
 Nevada contractor's drillers number 957
 Nevada driller's license number 957
 Signed Paul Williams Contractor
 Date 2-7-84

Date started 2-3 1984
 Date completed 2-7 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours