WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 2577
Permit No. [illegible]
Basin WASHOE V[illegible]-89

NOTICE OF INTENT NO. 3213

1. OWNER SMITH & SONS BUILDERS
MAILING ADDRESS 4355 GANDER LANE
WASHOE VALLEY, NV. - CARSON CITY, NV.

ADDRESS AT WELL LOCATION 4070 BLUE WING
NEW WASHOE CITY

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 17 N/S R. 20 E WASHOE County
PERMIT NO. ____ Issued by Water Resources | 5o-417-10 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	29	29
Brown-yellow Clay with D.G. , some Rock		29	170	141
D.G.-Black & Blue Clays W/Large Gravels	XX	170	180	
T.D. 180 Ft.				
There is 18" of Pea Gravel inside the Perforated Pipe.				

Date started 2-22, 19 84
Date completed 2-23, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with 150 lbs. of Air at 600 cfm, to clean & develop - 1½ hours.			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. 10" to 60' WELL CONSTRUCTION
Diameter hole 8 inches Total depth 180 feet
Casing record 6 5/8 .156
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+18" feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 180 feet

Perforations:
Type perforation FACTORY
Size perforation 3/32 X 3
From 158 feet to 180 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow 20 G.P.M. ____ P.S.I.
Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE, INC. Contractor
Address 2255 GLENDALE AVE. - SPARKS, NV. 89431
Roger M. Thrall Contractor
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132 Actual Driller
Signed Roger M Thrall
Roger M. Thrall Contractor
Date 2-23-84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434