

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. ....

1. OWNER CUSTOM BUILDERS ADDRESS AT WELL LOCATION .....  
 MAILING ADDRESS 3235 Elaine Way 11665 Deodar Way  
Sparks, NV 89431 Reno, NV 89506

2. LOCATION NW 1/4 SE 1/4 Sec. 15 T. 21N N/S R. 19 E. Washoe County  
 PERMIT NO. .... Lemmon Valley Subdivision Name  
 Issued by Water Resources Parcel No. ....

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Loose brown sand		3	6	3
Brown sandy clay		6	82	76
Fine brown sand loose		82	98	16
Cemented brown clay		98	132	36
Loose soft med. brown sand	x	132	139	7
Brown clay with cemented gravels (NO WATER)		139	145	6
Brown sandy clay		145	174	29
Weathered granite		174	179	5
Broken green granite	x	179	199	20
Green granite		199	210	11
Soft zone		210	213	3
Green granite		213	237	24
Light brown clay		237	245	8
Water Strata (132-139)		3 GPM		
" " (179-199)		4 GPM		
" " (210-215)		13 GPM		

8. WELL CONSTRUCTION  
 Diameter hole 10 x 6 inches Total depth 245 feet  
 Casing record 245  
 Weight per foot ..... Thickness 1.56

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>190</u> feet
<u>5" liner</u> inches	<u>120</u> feet	<u>245</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 245 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 2 1/2 x 6 around  
 From 164 feet to 186 feet  
 From 5" liner feet to ..... feet  
 From 125 feet to 245 feet  
 From ..... feet to ..... feet  
 From ..... feet to ..... feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Flow 20 G.P.M. P.S.I. ....  
 Water temperature cold °F. Quality clear

Date started 2-17-84, 19.....  
 Date completed 3-1-84, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number 14043  
 Nevada contractor's drillers number 908  
 Nevada driller's license number 923 Actual Driller  
 Signed Mary C. Hedman Contractor  
 Date March 14, 1984

BAILER TEST  
 G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours