WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25213 35213
Permit No. DOMESTIC
Basin LEMMON V. 7-92

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER MARC PLANTE
MAILING ADDRESS 11615 Heart Pine
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 21N N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Lemmon Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay with DG mixed		2	60	58
Soft zone		60	63	3
Brown clay		63	73	10
Soft zone		73	78	5
Brown clay		78	89	11
Soft zone	x	89	105	16
Brown clay sandy		105	117	12
Weather granite		117	133	16
Soft fracture granite				
NO WATER		133	143	10
Gray granite		143	163	20
Fracture granite	x	163	169	6
Gray granite		169	176	7
Fracture granite	x	176	186	20
Gray granite		186	190	4
Water Strata 89-105		5 GPM		
" " 163-169		8 GPM		
" " 176-186		37 GPM		

Date started 3-5-84, 19
Date completed 3-6-84, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 190 feet
Casing record 190
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
liner 5" inches	140 feet	190 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 190 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 110 feet to 142 feet
From feet to feet
From 170 feet to 190 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow 50 G.P.M. P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 14043
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed Gary C. Hedman (Contractor)
Date March 12, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434