WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25232
Permit No.
Basin TR. MEADOWS 6-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3215

1. OWNER LA CASA ARMS
MAILING ADDRESS 500 LINDEN ST.
RENO, NV. 89502

ADDRESS AT WELL LOCATION 500 LINDEN ST.
RENO, NV. 89502

2. LOCATION SE ¼ NE ¼ Sec. 24 T 19 N/S R 19 E WASHOE County
PERMIT NO. ____ Issued by Water Resources | 20-032-33 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE Heat Pump
Domestic [ ] Irrigation [ ] Test [X]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brinkerhoff drilled the first 250 feet. | | | | |
| Sands & Clays - cobbles | | 250 | 370 | 120 |
| Blue clay & sand | | 370 | 505 | 135 |
| T.D. 505 ft. | | | | |

Date started 2-8, 1984
Date completed 2-12, 1984

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Blew with Air to Clean & Develop 3 hrs. Blowing 50 GPM. Well was not completely cleaned up. Still has rusty-colored water. | | | |

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 505 feet
Casing record 6 5/8"
Weight per foot 10.78 Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | +12" feet | 505 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type SLURRY
Depth of seal 56 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 56 feet to 505 feet

Perforations:
Type perforation FACTORY
Size perforation 3/32 X 3
From ____ feet to ____ feet
From 461 feet to 505 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level flowing feet below land surface
Flow 3------ G.P.M. ____ P.S.I.
Water temperature 80 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AQUA DRILLING & WELL SERVICE, INC. (Contractor)
Address 2255 GLENDALE AVE. - SPARKS, NV. 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132
Signed Roger M Thrall (Actual Driller)
Roger M. Thrall (Contractor)
Date 3-23-84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434