WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25235
Permit No. DOMESTIC
Basin COLD SPRINGS 7-100
NOTICE OF INTENT NO. 3626

PRINT OR TYPE ONLY

1. OWNER John Lairson
MAILING ADDRESS 17870 Aspen Circle
Reno NV

ADDRESS AT WELL LOCATION Same

2. LOCATION ¼ NW ¼ Sec. 20 T. ~~18~~ 21 N/S R. ~~21~~ 18 E Washoe County
PERMIT NO. 1973 WNHOECo HEALTH (Issued by Water Resources) Lot 8 (Parcel No.) 704427 Northridge (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 12 | 12 |
| Sand | | 12 | 50 | 38 |
| Clay with streaks | | 50 | 140 | 90 |
| Rock | | 140 | 148 | 8 |
| Rock & Clay | | 148 | 212 | 64 |
| Corse Sand | | 212 | 218 | 6 |
| Clay | | 218 | 220 | 2 |

Date started 3/6, 19 84
Date completed 3/15, 19 84

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 15 Draw down 30 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 220 feet
Casing record 6 5/8
Weight per foot 12.89 Thickness 188

| Diameter | From | To |
|---|---|---|
| 6" inches | 0 feet | ~~200~~ feet |
| inches | feet | 220 feet |
| CASING inches | feet | feet |
| 6 5/8 inches | feet | feet |
| 6 5/8 inches | 0 feet | 220 feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow -0- G.P.M. P.S.I.
Water temperature C° F. Quality Unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Pump & Drilling Inc (Contractor)
Address 4639 Hiway 50 E. CC NV 89701 (Contractor)
Nevada contractor's license number 0122368
Nevada contractor's drillers number 1393
Nevada driller's license number 786
Signed Curtis Blodgett (Actual Driller) (Contractor)
Date 3/18/84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434