WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25248
Permit No. 45566
Basin 163

1. OWNER: O. H. Neckert ADDRESS: Sandy Valley, Nevada.

2. LOCATION: E 1/2 - E 1/2 S. E. 1/4 S. E 1/4 Sec. 36 T. 24 N/S R. 56 E. Clark County
PERMIT NO. 45566

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil.		0	9	9
Caliche.		9	15	6
Brown Sand Stone		15	20	5
White Lime Stone		20	30	10
Water bearing gravel	5'	30	35	5
Hard White Lime Stone		35	45	10
Gravel		45	50	5
Hard brown sand stone		50	60	10
Water bearing gravel	20	60	80	20
Hard brown sandstone		80	100	20
Gravel-water bearing	20	100	120	20
Hard white lime stone		120	140	20
Water bearing gravel	20	140	160	20
Brown Sand Stone		160	175	15
Water & gravel.	25	175	200	25

RECEIVED
APR 1 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started July, 1979
Date completed Mar. 25, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 200 feet
Casing record 6 5/8 x 200'
Weight per foot 62 lbs. Thickness .135

Diameter	From	To
6 5/8 OD inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Slot
Size perforation 1/8" x 6"
From 50 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 25' Feet below land surface
Flow ..... G.P.M.
Water temperature 62° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name H. V. Weimer
Address 9051 Mohawk L.V. Nev.
Nevada contractor's license number 5962 A
Nevada driller's license number 171
Signed H. V. Weimer
Date Mar. 30, 1980

USE ADDITIONAL SHEETS IF NECESSARY

5471